

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:178 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Model 4193SN Serial Number Interface Module (SIM). The module is an accessory for use with Ademco fire alarm control panels supporting polling loop devices. It is intended to be connected to the control unit's polling circuitry and provides point identification for devices which are provided only with a set of dry contacts. Model 4193SN must be installed within the control panel cabinet or inside a UL listed enclosure. For fire alarm, the supervised zone must be used. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 VDC, 3mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use only with Ademco's separately listed *fire alarm control units.

*Corrected 01-06-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager